

## **TABLE 1-6 FROM OSHA 1910.137**

### **Rubber Insulating Equipment Test Intervals**

<b>TYPE OF EQUIPMENT:</b>	<b>WHEN TO TEST:</b>
Rubber Insulating <b>LINE HOSE</b>	Upon Indication that insulating value is suspect
Rubber Insulating <b>COVERS</b>	Upon Indication that insulating value is suspect
Rubber Insulating <b>BLANKETS</b>	Before first issue and every 12 months thereafter. <sup>1</sup>
Rubber Insulating <b>GLOVES</b>	Before first issue and every 6 months thereafter. <sup>1</sup>
Rubber Insulating <b>SLEEVES</b>	Before first issue and every 12 months thereafter. <sup>1</sup>

<sup>1</sup> If the insulating equipment has been electrically tested but not issued for service, the insulating equipment may not be placed into service unless it has been electrically tested within the previous 12 months.



**IN OREGON, THE TESTING INTERVALS FOR  
RUBBER INSULATING GLOVES AND SLEEVES  
IS EVERY SIX MONTHS.  
SEE OAR 437-002-0138**