



THE FAIT

FIELD AIR INSPECTION TOOL

“ *Insulating equipment shall be inspected for damage before each day’s use and immediately following any incident that can reasonably be suspected of causing damage. Insulating gloves shall be given an air test, along with the inspection.* ”
- OSHA 1910.137(C)(2)(ii)

INFLATE. INSPECT. PROTECT.



✓ Safety First

***FAIT** ensures gloves are tested before use so crews stay safe as insulating rubber gloves can develop unseen punctures or leaks

*Inspect a pair of gloves in less than **2 minutes!**

HOW TO USE:

- 1** Flip the gloves inside out
- 2** Slide the cuff of the glove into the gap of the FAIT
- 3** Roll the glove over & around the FAIT
- 4** Flip gloves inside out & repeat



(creates tight seal for better air retention & superior visual inspection)

PART #: HJA-750

SAFETY ★ SERVICE ★ SAVINGS



Arnett Industries

Built on a legacy of innovation and service as a trusted leader in accredited testing services and manufacturing of diagnostic testing equipment for 50+ years.



503-692-4600

www.hjarnett.com
information@hjarnett.com

20460 SW Avery Ct
Tualatin, OR 97062



ARNETT TESTING LAB

NAIL-ACCREDITED RUBBER GLOVE & PPE TESTING LAB

OUR MISSION:

To protect those who power our communities by providing industry-leading, NAIL-accredited testing of rubber gloves and PPE, ensuring uncompromising safety and reliability.

TESTING SERVICES INCLUDE

- ✓ Rubber Gloves
- ✓ Rubber Blankets
- ✓ Rubber Sleeves
- ✓ Hotline Tools
- ✓ Insulating Hand Tools
- ✓ Grounding Cables
- ✓ Line Hose, Hoods, & Cover-Ups
- ✓ Rubber Overshoe & Switchboard Matting

HOW OFTEN SHOULD YOU TEST?

TABLE I-5 FROM OSHA 1910.137
Rubber Insulating Equipment Test Intervals

TYPE OF EQUIPMENT:	WHEN TO TEST:
Rubber Insulating GLOVES	Before first issue and every <u>6 months</u> thereafter. ¹
Rubber Insulating BLANKETS	Before first issue and every <u>12 months</u> thereafter. ¹
Rubber Insulating SLEEVES	Before first issue and every <u>12 months</u> thereafter. ¹
Rubber Insulating COVERS	Upon Indication that insulating value is suspect
Rubber Insulating LINE HOSE	Upon Indication that insulating value is suspect

¹ If the insulating equipment has been electrically tested but not issued for service, the insulating equipment may not be placed into service unless it has been electrically tested within the previous 12 months.



IN OREGON, THE TESTING INTERVALS FOR RUBBER INSULATING GLOVES AND SLEEVES IS EVERY SIX MONTHS. SEE OAR 437-002-0138



Need Your PPE Tested?

Please **PRINT** out the "Customer Intake Form" and send it to Arnett's electrical glove testing lab with the items you want tested. →

Standard turn-around time is 10-15 business days (call/check website for current lead times)

⚡ **Rush testing** is available — additional fees apply



Mobile On-Site Field Testing & Fault Locating
Hot Line Tools · Ground/Jumper Cable · Boom Truck · Hi-Pot Cable



CUSTOMER INTAKE FORM

503-692-4600

www.hjarnett.com
information@hjarnett.com

20460 SW Avery Ct
Tualatin, OR 97062